


Double Wall Exam Booth  
 Pit / Threshold Detail  
 4" Floor with 2 5/8" Isolation Rails

NOTE: Pit recess must be level to within 1/8" over 10', non-cumulative. Pit length and width must be a minimum of 4" larger than the booth, details will be shown on job approval drawings.

TITLE Pit / Threshold Detail	 <b>ACOUSTIC SYSTEMS</b> AUSTIN, TEXAS	DRAWN BY SMD	DATE 3/3/04
		CHKD BY	DATE
FOR Technical Manual	DRWG. NO. _____	NOTES For Proposal Only	
SHT. 1 OF 1	SCALE		